

Warrington



Township

*Water & Sewer Department
1585 Turk Road
Warrington, PA 18976*

*Office: 215-343-1800
Fax: 215-343-2281
www.wtwsd.org*

K. Fred Achenbach, Manager

WARRINGTON TOWNSHIP WATER & SEWER DEPARTMENT PROCEDURE FOR OBTAINING FIRE FLOW DATA ON THE PUBLIC WATER SYSTEM

1. Applicants must provide a description of their project including tax parcel number and street address. Upon request, the Township will provide the approximate static water pressure of the system in that area and the size of the nearest water main.
2. If more specific information is required, the applicant shall submit a **written** request to conduct fire hydrant tests. The Township will provide a copy of the system map in the area of the project showing the locations of mains and fire hydrants. The applicant shall submit a written request including the following items:
 - Purpose of test.
 - Requested date and time of tests.
 - Map showing test and residual fire hydrants.
3. After review and approval of plan, the Township will provide a State-certified water operator to observe the fire flow tests. The tests are to be conducted under the following guidelines:
 - The applicant shall provide qualified personnel and all necessary equipment to conduct the tests (personnel are required at all hydrants used in the tests).
 - The applicant shall provide all necessary diffusion devices and traffic controls to prevent property damage and traffic disruption.
 - **If applicant arrives at site unprepared to perform the tests in the manner set forth, the tests will be terminated and applicant will need to resubmit a request.**
 - At any time and for any reason the Township operator determines that the tests may cause property damage, disruption of traffic, or poses a risk to the public water system the test will be halted until all problems are resolved.